



## Planning Applications – Suggested Informative Statements and Conditions Report

If you would like to discuss any of the points in this document please contact us on 07929 786955 or email [planningliaison@anglianwater.co.uk](mailto:planningliaison@anglianwater.co.uk).

AW Site 196959/1/0158680

Reference:

Local Bedford (B)

Planning

Authority:

Site: Land At Bedford Road And High Street  
Roxton Bedfordshire

Proposal: Outline application with all matters reserved except access for up to 50 dwellings, site access and highway works, associated infrastructure, green infrastructure including sustainable drainage, ecological habitats, childrens play area, amenity green

Planning 22/02545/MAO  
application:

**Prepared by:** Pre-Development Team

**Date:** 30 December 2022

## ASSETS

### Section 1 - Assets Affected

There are assets owned by Anglian Water or those subject to an adoption agreement within or close to the development boundary that may affect the layout of the site. Anglian Water would ask that the following text be included within your Notice should permission be granted.

Anglian Water has assets close to or crossing this site or there are assets subject to an adoption agreement. Therefore the site layout should take this into account and accommodate those assets within either prospectively adoptable highways or public open space. If this is not practicable then the sewers will need to be diverted at the developers cost under Section 185 of the Water Industry Act 1991. or, in the case of apparatus under an adoption agreement, liaise with the owners of the apparatus. It should be noted that the diversion works should normally be completed before development can commence.

## **WASTEWATER SERVICES**

### **Section 2 - Wastewater Treatment**

The foul drainage from this development is in the catchment of Roxton Water Recycling Centre that will have available capacity for these flows

### **Section 3 - Used Water Network**

This response has been based on the following submitted documents: FRA & Drainage Strategy 19384-FRA-01\_v4 Nov 22; Development will lead to an unacceptable risk of flooding downstream. Anglian Water will need to plan effectively for the proposed development, if permission is granted. We will need to work with the applicant to ensure any infrastructure improvements are delivered in line with the development. A full assessment cannot be made due to lack of information outlining the connection to the public network, namely the rate of pumped discharge. We therefore request a condition requiring an on-site drainage strategy 1. INFORMATIVE - Notification of intention to connect to the public sewer under S106 of the Water Industry Act Approval and consent will be required by Anglian Water, under the Water Industry Act 1991. Contact Development Services Team 0345 606 6087. 2. INFORMATIVE - Notification of intention to connect to the public sewer under S106 of the Water Industry Act Approval and consent will be required by Anglian Water, under the Water Industry Act 1991. Contact Development Services Team 0345 606 6087. 3. INFORMATIVE - Protection of existing assets - A public sewer is shown on record plans within the land identified for the proposed development. It appears that development proposals will affect existing public sewers. It is recommended that the applicant contacts Anglian Water Development Services Team for further advice on this matter. Building over existing public sewers will not be permitted (without agreement) from Anglian Water. 4. INFORMATIVE - Building near to a public sewer - No building will be permitted within the statutory easement width of 3 metres from the pipeline without agreement from Anglian Water. Please contact Development Services Team on 0345 606 6087. 5. INFORMATIVE: The developer should note that the site drainage details submitted have not been approved for the purposes of adoption. If the developer wishes to have the sewers included in a sewer adoption agreement with Anglian Water (under Sections 104 of the Water Industry Act 1991), they should contact our Development Services Team on 0345 606 6087 at the earliest opportunity. Sewers intended for adoption should be designed and constructed in accordance with Sewers for Adoption guide for developers, as supplemented by Anglian Water's requirements.

### **Section 4 - Surface Water Disposal**

The preferred method of surface water disposal would be to a sustainable drainage system (SuDS) with connection to sewer seen as the last option. Building Regulations (part H) on Drainage and Waste Disposal for England includes a surface water drainage hierarchy, with infiltration on site as the preferred disposal option, followed by discharge to watercourse and then connection to a sewer.

From the details submitted to support the planning application the proposed method of surface water management does not relate to Anglian Water operated assets. As such, we are unable to provide comments on the suitability of the surface water management. The Local Planning Authority should seek the advice of the Lead Local Flood Authority or the Internal Drainage Board. The Environment Agency should be consulted if the drainage system directly or indirectly involves the discharge of water into a watercourse. Should the proposed method of surface water management change to include interaction with Anglian Water operated assets, we would wish to be re-consulted to ensure that an effective surface water drainage strategy is prepared and implemented. We note the applicant states the SuDS scheme will be adopted by Anglian Water. As yet the applicant has not engaged with us, therefore we cannot comment, at this stage, on the proposals suitability. Anglian Water encourage the use of SuDS and if the developer wishes us to be the adopting body for all or part of the proposed SuDS scheme the Design and Construction Guidance must be followed. We would recommend the applicant contact us at the earliest opportunity to discuss their SuDS design via a Pre-Planning Strategic Enquiry, please contact [planningliaison@anglianwater.co.uk](mailto:planningliaison@anglianwater.co.uk)

## Section 5 - Suggested Planning Conditions

Anglian Water would therefore recommend the following planning condition if the Local Planning Authority is mindful to grant planning approval.

### Used Water Sewerage Network (Section 3)

We have no objection subject to the following condition: Condition Prior to the construction above damp proof course, a scheme for on-site foul water drainage works, including connection point and discharge rate to the public network, shall be submitted to and approved in writing by the Local Planning Authority. Reason To prevent environmental and amenity problems arising from flooding

### FOR THE ATTENTION OF THE APPLICANT - if Section 3 or Section 4 condition has been recommended above, please see below information:

#### Next steps

Desktop analysis has suggested that the proposed development will lead to an unacceptable risk of flooding downstream. We therefore highly recommend that you engage with Anglian Water at your earliest convenience to develop in consultation with us a feasible drainage strategy.

If you have not done so already, we recommend that you submit a Pre-planning enquiry with our Pre-Development team. This can be completed online at our website <http://www.anglianwater.co.uk/developers/pre-development.aspx>

Once submitted, we will work with you in developing a feasible mitigation solution.

If a foul or surface water condition is applied by the Local Planning Authority to the Decision Notice, we will require a copy of the following information prior to recommending discharging the condition:

#### Foul water:

- Feasible drainage strategy agreed with Anglian Water detailing the discharge solution including:
  - Development size
  - Proposed discharge rate (Should you require a pumped connection, please note that our minimum pumped discharge rate is 3.8l/s)
  - Connecting manhole discharge location (No connections can be made into a public rising main)
- Notification of intention to connect to the public sewer under S106 of the Water Industry Act (More information can be found on our website)
- Feasible mitigation strategy in agreement with Anglian Water (if required)